

# NSF International

RECOGNIZES

## BELIMO AIRCONTROLS

DANBURY, CT

AS COMPLYING WITH NSF/ANSI 61 AND ALL APPLICABLE REQUIREMENTS.  
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE  
AUTHORIZED TO BEAR THE NSF MARK.



ANSI Accredited Program  
PRODUCT CERTIFICATION  
Certification Program  
Accredited by the  
American National  
Standards Institute



Certification Program  
Accredited by the  
Standards Council  
of Canada

This certificate is the property of NSF International and must be returned upon request. For the most current and complete information, please access NSF's website ([www.nsf.org](http://www.nsf.org)).

December 23, 2009  
Certificate# C0000181 - 01

David Purkiss, General Manager  
Water Distribution Systems



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on December 16, 2009.

BELIMO AIRCONTROLS
43 OLD RIDGEBURY ROAD
DANBURY, CT 06810
800-543-9038
203-791-9915

Facility: DANBURY, CT

Mechanical Devices

Table with 4 columns: Trade Designation, Size, Water Contact Temp, Water Contact Material. Rows include HTCCV Valve B215HT, B220HT, and B225HT with various configurations.

- [1] A: Cv flow (029, 046, 073, 116, 186, 290, 455, 464, 731, 928, 1320, 1160, 1856, or 2800)
B: Actuator Type (TR, LR, TF or LF)
C: Power Supply (24 or 120)
D: Control (Blank, 3, SR, MFT or S)
E: Configuration (NO, NC, NO/FO, NO/FC, NC/FO, NC/FC)

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.