

DECLARATION OF CONFORMITY

Name: Kele, Inc.

Address: 3300 Brother Boulevard
Bartlett, TN 38133

Declares the product Series

Type: Compact Power and Energy Meter

Models: Series GPxxx

Conforms to the following:

European Union Low Voltage Directive 2006/95/EC

Standard Applied EN 61010-1:2001 Safety requirements for electrical equipment for measurement, control and laboratory use – Part 1: General requirements

European Union EMC Directive 2004/108/EC

Emission Standards Applied

Test Description	Specification	Test Method	Pass/Fail
Radiated Emissions	EN 61000-6-3:2007 Class B	CISPR 22:2005 (Amended by A1:2005 and A2:2006)	P
Conducted Emissions	EN 61000-6-3:2007 Class B	CISPR 22:2005 (Amended by A1:2005 and A2:2006)	P
Conducted Emissions	EN 61000-6-4:2007 Class A	CISPR 22:2005 (Amended by A1:2005 and A2:2006)	P
Current Harmonics	EN 61000-3-2: 2006	EN 61000-3-2: 2005	P
Flicker	EN 61000-3-3: 1995 (Amended by A1:2001 and A2:2005)	EN 61000-3-3: 2005	P

Immunity Standards Applied

Test Description	Specification	Test Method	Criteria
Voltage Dips & Interrupts	EN 61000-6-2:2005- Industrial	EN 61000-4-11:2004	2
ESD	EN 61000-6-2:2005- Industrial	EN 61000-4-2:2001	1
Radiated Immunity	EN 61000-6-2:2005- Industrial	EN 61000-4-3:2006 (Amended by A1:2007)	1
EFT	EN 61000-6-2:2005- Industrial	EN 61000-4-4:2004	1
Surge	EN 61000-6-2:2005- Industrial	EN 61000-4-5:2005	1
Conducted Immunity	EN 61000-6-2:2005- Industrial	EN 61000-4-6:2006	1
Magnetic Field Immunity	EN 61000-6-2:2005- Industrial	EN 61000-4-8:2001	1

On behalf of Kele, Inc.

Name:

Title:

Signature:

Date:
