



MANUFACTURER: Greystone Energy Systems Inc.
150 English Drive, Moncton, New Brunswick, Canada, E1E 4G7

DECLARES THAT THE FOLLOWING PRODUCT:

PRODUCT NAME: WLD Series Water Leak Detector

MODEL NUMBERS: WLD2A Dual Channel Input Model
(where A designates Conductive, Remote or Spot cable configuration)

MODEL NUMBERS: WLDBX Single Channel Input Model
(where B designates Conductive, Remote or Spot cable configuration)
(where X designates 1 or 2 Relay output configuration)



CONFORMS TO THE FOLLOWING DIRECTIVES AND STANDARDS:

RoHS 3 Directive: 2015/863 Restriction of Hazardous Substances

EMC Directive: 2014/30/EU Electromagnetic Compatibility

Specification	Test Method	Description
EN 61326-1:2013	CISPR 11:2015 +A1:2016	Conducted and Radiated Emissions
	IEC 61000-4-2:2008	Electrostatic Discharge (ESD)
	IEC 61000-4-3:2010	Radiated Immunity
	IEC 61000-4-4:2012	Electrical Fast Transient and Bursts (EFT)
	IEC 61000-4-6:2013	Conducted Immunity
	IEC 61000-4-8:2009	Magnetic Field Immunity
FCC 15.109(g):2021 FCC 15.109:2021 FCC 15.107:2021 ICES-003:2020	ANSI C63.4:2014	Conducted and Radiated Emissions
	ANSI C63.4:2014	Conducted and Radiated Emissions



I, the undersigned, hereby declare that the equipment specified above conforms to the above Directive and Standard.

Bruce Hicks, Engineering Manager

February 18th, 2021
Moncton, NB, Canada